



NOTES:

PAVEMENT SECTION THICKNESS - $6 \frac{3}{8}'' = T$ (T shall be a minimum of 6'')
 1.26 C.F. CONCRETE PER L.F.

*TOP OF PAVEMENT MUST BE FLUSH TO THE GUTTER AT ALL HANDICAP RAMPS.
 SLOPE OF THE GUTTER PAN SHALL NOT EXCEED 1.5% AT ALL HANDICAP RAMPS

ALL EXPOSED SURFACES OF CONCRETE CURB AND GUTTER
 SHALL HAVE A BROOM FINISH

<p>CHRIS E. BAUSERMAN, P.E., P.S. Delaware County Engineer</p>	<p>STANDARD CONSTRUCTION DRAWING</p> <p>6 INCH CONCRETE COMBINED CURB & GUTTER</p> <p>(FOR LOCAL ROADS)</p>	<p>DELAWARE COUNTY ENGINEER'S OFFICE 50 Channing Street Delaware, Ohio 43015 PHONE: (740)833-2400 FAX: (740)833-2399 www.co.delaware.oh.us</p>
<p>APPROVED 1-22-2008</p>	<p>REVISER 10-21-2014</p>	<p>Drawn <u>KS</u> sheet <u>1</u> FILE NO. Checked <u>EM</u> of <u>1</u> DCED-R2010</p>