

PAVEMENT SECTION THICKNESS -83/8" = T1.59 C.F. CONCRETE PER L.F.

ALL EXPOSED SURFACES OF CONCRETE CURB AND GUTTER SHALL HAVE A BRUSH FINISH.

\* TOP OF PAVEMENT MUST BE FLUSH TO THE GUTTER AT ALL HANDICAP RAMPS. SLOPE OF THE GUTTER PAN SHALL NOT EXCEED 1.5% AT ALL HANDICAP RAMPS.

CHRIS E. BAUSERMAN, P.E., P.S	STANDARD CONSTRUCTION DRAWING	DELAWARE COUNTY ENGINEER'S OFFICE
Delaware County Engineer		50 Channing Street
, ,	8-INCH CONCRETE	Delaware, Ohio 43015
	COMBINED CURB &	PHONE: (740)833-2400 FAX: (740)833-2399
Delaware County Engineer	GUTTER	www.co.delaware.oh.us
APPROVED REVISED 1-04-2010	· · - · · · - · · ·	Drawn KS sheet 1 FILE NO.   Checked EM of 1 DCED-R2020
		01 =   0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0