

PAVEMENT SECTION THICKNESS -93/8" = T * MAXIMUM GUTTER PAN CROSS SLOPE AT ALL HANDICAP RAMPS = 1.5%. TOP OF PAVEMENT MUST BE FLUSH TO GUTTER AT ALL HANDICAP RAMPS.

ALL EXPOSED SURFACES OF CONCRETE CURB AND GUTTER SHALL HAVE A BRUSH FINISH.

DELAWARE COUNTY ENGINEER'S OFFICE CHRIS E. BAUSERMAN, P.E., P.S. STANDARD CONSTRUCTION DRAWING TYPE 2 HEAVY DUTY 50 Channing Street Delaware County Engineer 9-INCH CONCRETE Delaware, Ohio 43015 COMBINED CURB & PHONE: (740)833-2400 FAX: (740)833-2399 Delaware County Engineer www.co.delaware.oh.us **GUTTER** APPROVED REVISED FILE NO. (FOR ARTERIAL & MAJOR Drawn 1-04-2010 COLLECTOR ROADS) KS 1 DCED-R2022 Checked_