


DETAIL A

200' ENTRANCE STREET LENGTH
(INCLUDING 50' DIVERGENT TAPER)

- LEGEND**
- A. 1-1/2" ASPHALT CONCRETE SURFACE COURSE, ITEM 404
 - B. 1-1/2" ASPHALT CONCRETE INTERMEDIATE COURSE, ITEM 402
 - C. 6" BITUMINOUS AGGREGATE BASE, ITEM 301
 - D. 4" CRUSHED AGGREGATE BASE, ITEM 304
 - E. CRUSHED AGGREGATE BERM, ITEM 304 (SEE NOTE 1 BELOW).
 - F. BITUMINOUS PRIME COAT, ITEM 408, 702.02 RC-250, MC-30, MC-70 OR MC 250 (APPLIED AT 0.40 GAL. PER SQ. YD.)
 - G. SEAL COAT, ITEM 409, 702.02, RC-250, RC-800, MC-800, MC-3000, 702.03, CBAE-800 OR 702.04, RS-1, RS-2, CRS-1, CRS-2 (USING 0.30 GAL. BITUMINOUS MATERIAL PER SQ. YD.) AND .008 CU.YD. COVER AGGREGATE PER SQ. FT.
 - H. 4" PIPE UNDERDRAIN, ITEM 605
 - I. NO.8 OR NO. 57 AGGREGATE
 - J. SEEDING AND MULCHING, ITEM 659
- NOTES:**
1. VERIFY WITH TOWNSHIP WHETHER TO PROVIDE REINFORCED SHOULDER PER STANDARD DRAWING DCED-R2137.
 2. A 5' DRAINAGE AND UTILITY EASEMENT IS REQUIRED FOR PORTION OF REMAINING DITCH BACKSLOPE OUTSIDE OF R/W.
 3. THE MINIMUM DITCH DEPTH SHALL BE 1.5'.

CHRIS E. BAUSERMAN, P.E., P.S.
Delaware County Engineer



Delaware County Engineer

APPROVED 1-04-2010

REVISED

STANDARD CONSTRUCTION DRAWING
LOCAL STREET
ENTRANCE
SECTION AND DETAIL

36' EP/EP

200 VPD < ADT < 1500 VPD

DELAWARE COUNTY ENGINEER'S OFFICE
50 Channing Street
Delaware, Ohio 43015
PHONE: (740)833-2400 FAX: (740)833-2399
www.co.delaware.oh.us

Drawn MR sheet 1 of 1 FILE NO. DCED-R2135G
Checked EM