



** ITEM 304, AGGREGATE BASE SHALL BE ELIMINATED WHEN ITEM 636 CONTROLLED DENSITY FILL (TYPE I OR II) IS USED FOR COMPACTED BACKFILL.

ALL MATERIALS AND CONSTRUCTION SHALL CONFORM TO THE DELAWARE COUNTY DESIGN, CONSTRUCTION AND SURVEYING STANDARDS MANUAL, CURRENT EDITION.

TYPE I OR II BACKFILL OF ALL TRENCHES SHALL BE IN ACCORDANCE WITH SECTION 911. PERMANENT RE-PAVEMENT SHALL NOT BE DONE UNTIL APPROVED BY THE ENGINEER. THE EDGE SHALL BE CUT VERTICAL AND TRIMMED TO PROVIDE A STRAIGHT LINE. ALTERNATE BACKFILL MAY BE CONTROLLED DENSITY FILL AS PER ITEM 636, TYPE I OR II, OR COMPACTED AGGREGATE BACKFILL AS PER ITEM 912. TACK COAT, ITEM 407 SHALL BE BITUMINOUS MATERIAL, 702.02, RC-70, RC-250 OR 702.04, RS-1, RS-2 OR MS-2, APPLIED AT A RATE OF 0.1 GAL. PER SQ. YD. JOINT SEALER SHALL MEET THE REQUIREMENTS OF ITEM 413 TYPE I.

CHRIS E. BAUSERMAN, P.E., P.S.

Delaware County Engineer

Delaware County Engineer

STANDARD CONSTRUCTION DRAWING

PAVEMENT REPLACEMENT
(DRIVEWAYS)

DELAWARE COUNTY ENGINEER'S OFFICE

50 Channing Street

Delaware, Ohio 43015

PHONE: (740)833-2400

FAX: (740)833-2399

www.co.delaware.oh.us

APPROVED

1-04-2010

REVISED

Drawn MAS
Checked DWR

sheet 1
of 1

FILE NO.

DCED-R2160