



IF A BORE PUSH IS IN CONFLICT WITH A STORM RUN, THE CONDUIT OR CASING SHALL BE A MIN. OF 18" BELOW THE STORM.

PAVEMENT REPLACEMENT SHALL BE AS PER STANDARD DRAWING DCED-R1441 DRAWINGS A-C.

* PUSH AND RECEIVER PITS TO BE A MINIMUM OF 5 FEET FROM THE BACK OF CURB OR EDGE OF PAVEMENT. SEE SHEET 2 OF 2.

CHRIS E. BAUSERMAN, P.E., P.S. Delaware County Engineer		STANDARD CONSTRUCTION DRAWING TYP. UTILITY BORE REQUIREMENTS		DELAWARE COUNTY ENGINEER'S OFFICE 50 Channing Street Delaware, Ohio 43015 PHONE: (740)833-2400 FAX: (740)833-2399 www.co.delaware.oh.us	
<i>Delaware County Engineer</i>				Drawn <u>KS</u>	FILE NO.
APPROVED 1-22-2008	REVISED 1-04-2010			sheet <u>1</u> of <u>2</u>	DCED-R2166A
				Checked <u>EM</u>	