



NOTE:

1. Joints and connections shall be as specified under 604.06
2. Manholes must be in accordance with ASTM C-478.
3. Precast walls shall have a minimum thickness of 5 inches and reinforced sufficiently to permit shipping and handling without damage.
4. If INV. to T/C is less than 4.5' refer to DCED-S100, DCED S-114 thru DCED S-116

CHRIS E. BAUSERMAN, P.E., P.S.
Delaware County Engineer

STANDARD CONSTRUCTION DRAWING

DELAWARE COUNTY ENGINEER'S OFFICE
50 Channing Street
Delaware, Ohio 43015
PHONE: (740)833-2400 FAX: (740)833-2399
www.co.delaware.oh.us

TYPE "C" MANHOLE
48" thru 96" PRECAST BASE

APPROVED
1-22-2008

REVISED
1-04-2010

Drawn KS sheet 1 FILE NO.
Checked EM of 2 DCED-S102A