



NOTES:

- 1. STAINLESS STEEL
- 2. NEMA 4
- 3. HANDLE WITH DEFEATER PADLOCK HASP
- 4. 1/2" PREFORMED JOINT FILLER AS PER CMS 705.03 SHALL BE USED BETWEEN FOUNDATIONS AND ADJACENT PAVED AREAS.
- 5. THE SIZE, NUMBER AND LOCATION OF ANCHOR BOLTS SHALL BE IN ACCORDANCE WITH THE MANUFACTURERS RECOMMENDATION.
- 6. CABINETS SHALL BE SEALED TO THE FOUNDATION WITH A FLEXIBLE, WEATHERPROOF, CLEAR, SILICONE CAULKING COMPOUND.

DELAWARE COUNTY ENGINEER	
DRAWING NO. LIGHTING CONTROL CENTER REV. #1	REV. DATE 3/2/17

STANDARD CONSTRUCTION DRAWING
 LIGHTING CONTROL CENTER
 XXXXXX
 120VOLT
 SHEET NO.
 | OF |

CHRIS E. BAUSERMAN, P.E., P.S.
 DELAWARE COUNTY ENGINEER
 50 CHANNING STREET
 DELAWARE, OHIO 43015
 PHONE: (740)833-2400 FAX: (740)833-2399
 WWW.DELAWARECOUNTYENGINEER.ORG